

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 7125-1062:128 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Detection Systems, Inc., 130 Perinton Parkway, Fairport, NY 14450  
Contact: Frank Mioduszewski \*(585) 223-4060

DESIGN: Models ST24-15, ST24-15/75, ST24-30, ST24-60, ST24-75, ST24-110, GES24-15, GES24-15/75, GES24-30, GES24-60, GES24-75 and GES24-110 strobe lights; followed by suffix -W (wall mount), followed by -W or -R (white or red). Intended for indoor use and wall mount only. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Candela: 15cd, 15cd & 75cd at 0° angle axis  
30cd, 60cd, 75cd, 110cd  
Electrical: 21-30 VDC  
Flash Rate: 60 flashes per minute

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and candela ratings and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired for use with separately listed compatible fire alarm control units. For indoor use and wall mount only.

XLF: 7125-0569:123

\*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager